

QUOTATION FORM					
Name of Work : Oil Filtration of OSF Unit, 500 KVA Transformer oil filtration with OLTC Oil Filtration, Servicing of Air Circuit Breaker in Main LT Panel, Servicing of 250KVA and 100 KVA DG sets at Balbharati Campus, S.B. Road, Pune - 411004 and Oil filtration of OSF Unit, 315 KVA Transformer oil filtration work, Servicing of 62.5 KVA DG set at E-Balbharati, Agharkar Road, Pune - 411004					
Sr. No.	Item/work Description	Quantity	Unit	Rate	Total Amount
For Oil Switch Fuse Unit at Balbharati					
1	Filtration of Oil Switch Fuse Unit's oil on site till satisfactory test results	200	Litre		
2	Supplying and topping up filtered transformer oil of approved litre make with test certificate	50	Litre		
3	Liaisoning Charges for Shut Down electricity	1	Job		
For 500 KVA Transformer at Balbharati					
4	Filtration of Transformer oil on site till satisfactory test results	1160	Litre		
5	Supplying and topping up filtered transformer oil of approved litre make with test certificate	300	Litre		
6	Servicing of Online Tap Changer	1	Job		
7	Replacement of Silica Gel	1	Job		
8	Arresting of Oil Leakage from OLTC Shaft	2	Job		
9	Transport Charges for Oil Filter Plant	1	Visit		
For Servicing of 250 KVA DG Set at Balbharati					
10	Supply of KOEL CARE Super Genuine Oil 20 Litre CAN	1	Nos		
11	Supply of KOEL CARE Super Genuine Oil 5 Litre CAN	2	Nos		
12	Supply of Fuel Filter Kit 1.1 Litre	1	Nos		
13	Supply of Spin on Lube Oil Filter	2	Nos		
14	Supply of Air Cleaner Primary Element	1	Nos		
15	Supply of Air Cleaner Safety Element	1	Nos		
16	Consumables for Servicing	1	Set		
17	Carrying out Servicing of DG set from 62.5 kVA to 200 kVA	1	Job		
For Servicing of 100 KVA DG Set at Balbharati					
18	Supply of Oil Filter	1	Nos		
19	Supply of Fuel Filter	1	Nos		
20	Supply of Coolant, Additive Concrete	1	Nos		
21	Supply of Engine Oil, Valvoline Blue 7800, 20 Litre CAN	1	Nos		
22	Supply of Fuel Strainer	1	Nos		
23	Consumables for Servicing	1	Set		
24	Carrying out Servicing of DG set from 62.5 kVA to 200 kVA	1	Job		

For Main LT Panel at Balbharati					
25	Servicing of Air Circuit Breaker in Main LT Panel	2	Job		
For Oil Switch Fuse Unit at E-Balbharati					
26	Filtration of Oil Switch Fuse Unit's oil on site till satisfactory test results	200	Litre		
27	Supplying and topping up filtered transformer oil of approved litre make with test certificate	50	Litre		
28	Liaisoning Charges for Shut Down electricity	1	Job		
For 315 KVA Transformer at E-Balbharati					
29	Filtration of Transformer oil on site till satisfactory test results	400	Litre		
30	Supplying and topping up filtered transformer oil of approved litre make with test certificate	100	Litre		
31	Replacement of Silica Gel	1	Job		
32	Transport Charges for Oil Filter Plant	1	Visit		
For Servicing of 62.5 KVA DG Set at Balbharati					
33	Supply of Oil Filter	1	Nos		
34	Supply of Fuel Filter	1	Nos		
35	Supply of Coolant, Additive Concrete	1	Nos		
36	Supply of Engine Oil, Valvoline Blue 7800, 20 Litre CAN	1	Nos		
37	Supply of Fuel Strainer	1	Nos		
38	Consumables for Servicing	1	Set		
39	Carrying out Servicing of DG set from 62.5 kVA to 200 kVA	1	Job		

Total Cost	
GST 18%	
Total Cost of Work	

Seal & Signature of Contractor with address and Mobile No.